



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

China Primary School
763 Lakeview Drive
China, ME 04926

Date Printed: 07/06/2022
Work Order #: 2205-01644
Client Job #: 136
Date Received: 05/11/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/06/2022
CLIENT NAME: China Primary School

CLIENT ADDRESS: 763 Lakeview Drive
 China, ME 04926

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/11/2022 07:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 136

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01644-001	Kitchen, Bathroom - Sink	I	OT	05/07/2022 12:03PM	2.9	ppb			DR-NH	06/27/2022 11:37PM
2205-01644-002	Kitchen, Handwash - Sink Hot Side	I	OT	05/07/2022 12:04PM	3.5	ppb			DR-NH	06/27/2022 11:40PM
2205-01644-003	Kitchen, Sanatize Station A - Sink	I	KF	05/07/2022 12:06PM	17.2	ppb			DR-NH	06/27/2022 11:58PM
2205-01644-004	Kitchen, Sanatize Station B - Sink	I	KF	05/07/2022 12:07PM	3.9	ppb			DR-NH	06/28/2022
2205-01644-005	Kitchen, Veggie Wash - Sink	I	KF	05/07/2022 12:08PM	8.0	ppb			DR-NH	06/28/2022 12:03AM
2205-01644-006	Kitchen, Dishwash - Sink	I	KF	05/07/2022 12:09PM	9.8	ppb			DR-NH	06/28/2022 12:06AM
2205-01644-007	Cafeteria - BOTTLE FILL STATION	I	DWF	05/07/2022 12:11PM	<1	ppb			DR-NH	06/28/2022 12:09AM
2205-01644-008	Cafeteria - DWF	I	DWF	05/07/2022 12:11PM	<1	ppb			DR-NH	06/28/2022 12:12AM
2205-01644-009	Cafeteria, Handwash A - Sink	I	KF	05/07/2022 12:13PM	1.7	ppb			DR-NH	06/28/2022 12:15AM
2205-01644-010	Cafeteria, Handwash B - Sink	I	KF	05/07/2022 12:14PM	2.7	ppb			DR-NH	06/28/2022 12:18AM
2205-01644-011	Gym Boys Bathroom - Sink	I	KF	05/07/2022 12:17PM	2.6	ppb			DR-NH	06/28/2022 12:21AM
2205-01644-012	Gym - BOTTLE FILL STATION	I	DWF	05/07/2022 12:18PM	<1	ppb			DR-NH	06/28/2022 12:24AM
2205-01644-013	Gym - DWF	I	DWF	05/07/2022 12:18PM	<1	ppb			DR-NH	06/28/2022 12:39AM
2205-01644-014	Gym Girl Bathroom - Sink	I	OT	05/07/2022 12:19PM	2.6	ppb			DR-NH	06/28/2022 12:41AM
2205-01644-015	Staff Lounge - Sink	I	OT	05/07/2022 12:22PM	11.6	ppb			DR-NH	06/28/2022 12:44AM
2205-01644-016	Staff Lounge - DWF/Sink Combo	I	OT	05/07/2022 12:22PM	31.8	ppb			DG-NH	07/05/2022 04:12PM
2205-01644-017	Nurse Station - Sink	I	OT	05/07/2022 12:25PM	2.0	ppb			DG-NH	07/05/2022 04:16PM
2205-01644-018	Nurse Station B. Room - Sink	I	OT	05/07/2022 12:26PM	2.5	ppb			DR-NH	06/28/2022 12:47AM
2205-01644-019	Restroom across from Staff Lounge - Sink	I	OT	05/07/2022 12:27PM	1.1	ppb			DR-NH	06/28/2022 12:50AM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/06/2022
CLIENT NAME: China Primary School
CLIENT ADDRESS: 763 Lakeview Drive
 China, ME 04926
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 05/11/2022 07:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 136

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01644-020	Main Office Work - Sink	I	OT	05/07/2022 12:29PM	4.6	ppb	!		DR-NH	06/28/2022 12:53AM
2205-01644-021	Custodian Office - Sink	I	OT	05/07/2022 12:30PM	9.9	ppb	!		DR-NH	06/28/2022 12:56AM
2205-01644-022	RM 21, Bathroom - Sink	I	OT	05/07/2022 12:32PM	1.5	ppb			DR-NH	06/28/2022 12:59AM
2205-01644-023	RM 21 - Sink	I	OT	05/07/2022 12:33PM	11.0	ppb	!		DR-NH	06/28/2022 01:11AM
2205-01644-024	RM 22 - Sink	I	OT	05/07/2022 12:36PM	13.2	ppb	!		DR-NH	06/28/2022 01:14AM
2205-01644-025	Across frm RM 12, Staff RSTRM, - SINK	I	OT	05/07/2022 12:37PM	1.5	ppb			DR-NH	06/28/2022 01:22AM
2205-01644-026	RM 12 - Sink	I	OT	05/07/2022 12:39PM	9.5	ppb	!		DR-NH	06/28/2022 01:25AM
2205-01644-027	RM 13 - Sink	I	OT	05/07/2022 12:41PM	6.0	ppb	!		DR-NH	06/28/2022 01:28AM
2205-01644-028	RM 14 - Sink	I	OT	05/07/2022 12:41PM	11.0	ppb	!		DR-NH	06/28/2022 01:31AM
2205-01644-029	RM 15 - Sink	I	OT	05/07/2022 12:43PM	10.1	ppb	!		DR-NH	06/28/2022 01:34AM
2205-01644-030	RM 15 - DWF/Sink Combo	I	DWF	05/07/2022 12:43PM	8.7	ppb	!		DR-NH	06/28/2022 01:37AM
2205-01644-031	RM 16 - Sink	I	OT	05/07/2022 12:45PM	9.5	ppb	!		DR-NH	06/28/2022 01:46AM
2205-01644-032	RM 16 - DWF/Sink Combo	I	DWF	05/07/2022 12:45PM	10.4	ppb	!		DR-NH	06/28/2022 01:49AM
2205-01644-033	RM 17 - Sink	I	OT	05/07/2022 12:48PM	11.3	ppb	!		DR-NH	06/28/2022 01:52AM
2205-01644-034	Next to RM 17 - BOTTLE FILL STATION	I	DWF	05/07/2022 12:49PM	<1	ppb			DR-NH	06/28/2022 01:55AM
2205-01644-035	Next to RM 17 - DWF	I	DWF	05/07/2022 12:49PM	<1	ppb			DR-NH	06/28/2022 02:03AM
2205-01644-036	RM 18 - Sink	I	OT	05/07/2022 12:50PM	7.6	ppb	!		DR-NH	06/28/2022 02:06AM
2205-01644-037	RM 23, Bathroom - Sink	I	OT	03/07/2022 12:53PM	9.9	ppb	!		DR-NH	06/28/2022 02:09AM
2205-01644-038	Rm 23 - Sink	I	OT	05/07/2022 12:54PM	7.8	ppb	!		DR-NH	06/28/2022 02:12AM
2205-01644-039	Rm 23 - DWF/Sink Combo	I	DWF	05/07/2022 12:54PM	16.8	ppb	X		DR-NH	06/28/2022 02:24AM
2205-01644-040	Guidance - Sink	I	OT	05/07/2022 12:56PM	18.8	ppb	X		DR-NH	06/28/2022 02:27AM
2205-01644-041	Library, Workroom - Sink	I	OT	05/07/2022 12:59PM	2.6	ppb			DR-NH	06/28/2022 02:30AM
2205-01644-042	RM 31 - Sink	I	OT	05/07/2022 01:01PM	21.3	ppb	X		DR-NH	06/28/2022 02:33AM
2205-01644-043	RM 33 - Sink	I	OT	05/07/2022 01:02PM	15.7	ppb	X		DR-NH	06/28/2022 02:36AM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/06/2022
CLIENT NAME: China Primary School

CLIENT ADDRESS: 763 Lakeview Drive
China, ME 04926

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/11/2022 07:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 136

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01644-044	Across frm 31 - BOTTLE FILL STATION	I	DWF	05/07/2022 01:03PM	<1	ppb			DR-NH	06/28/2022 02:38AM
2205-01644-045	Across frm 31 - DWF	I	DWF	05/07/2022 01:03PM	<1	ppb			DR-NH	06/28/2022 02:47AM
2205-01644-046	Across frm 31, staff bathroom - Sink	I	OT	05/07/2022 01:04PM	1.6	ppb			DR-NH	06/28/2022 02:50AM
2205-01644-047	Across from 31, Boys BathRM, Sink A	I	OT	05/07/2022 01:07PM	1.9	ppb			DR-NH	06/28/2022 02:59AM
2205-01644-048	Across from 31, Boys BathRM, Sink B	I	OT	05/07/2022 01:07PM	2.4	ppb			DR-NH	06/28/2022 03:02AM
2205-01644-049	Across from 31, Boys BathRM, Sink C	I	OT	05/07/2022 01:07PM	1.4	ppb			DR-NH	06/28/2022 03:05AM
2205-01644-050	RM 28 - Sink	I	OT	05/07/2022 01:10PM	8.5	ppb			DR-NH	06/28/2022 03:08AM
2205-01644-051	RM 29 - Sink	I	OT	05/07/2022 01:11PM	10.6	ppb			DR-NH	06/28/2022 03:11AM
2205-01644-052	RM 30 - Sink	I	OT	05/07/2022 01:13PM	14.8	ppb			DR-NH	06/28/2022 03:14AM
2205-01644-053	RM 30 - DWF/Sink Combo	I	DWF	05/07/2022 01:13PM	9.8	ppb			DR-NH	06/28/2022 03:16AM
2205-01644-054	Across frm 33, Girl B. RM - Sink A	I	OT	05/07/2022 01:16PM	1.8	ppb			DR-NH	06/28/2022 03:19AM
2205-01644-055	Across frm 33, Girl B. RM - Sink B	I	OT	05/07/2022 01:16PM	2.7	ppb			DR-NH	06/28/2022 09:07PM
2205-01644-056	Across frm 33, Girl B. RM - Sink C	I	OT	05/07/2022 01:16PM	1.9	ppb			DR-NH	06/28/2022 09:10PM
2205-01644-057	RM 32 - Sink	I	OT	05/07/2022 01:18PM	15.0	ppb			DR-NH	06/28/2022 09:13PM
2205-01644-058	RM 34 - Sink	I	OT	05/07/2022 01:21PM	13.2	ppb			DR-NH	06/28/2022 09:16PM
2205-01644-059	RM 35- Sink	I	OT	05/07/2022 01:22PM	11.5	ppb			DR-NH	06/28/2022 09:19PM
2205-01644-060	RM 36 - Sink	I	OT	05/07/2022 01:24PM	13.4	ppb			DR-NH	06/28/2022 09:22PM
2205-01644-061	RM 37 - Sink	I	OT	05/07/2022 01:25PM	10.7	ppb			DR-NH	06/28/2022 09:25PM
2205-01644-062	Outside, Near Boiler, Playground - Hosebib	I	OT	05/07/2022 01:32PM	19.8	ppb			DG-NH	07/05/2022 04:19PM

Rebecca L. Labranche
Laboratory Director