

School Fixtures with Elevated Lead Results (exceeding 4 parts per billion)

China Middle School

	Collection Date	Collection site	Concentration (ppb)
1	5/7/2022	Men's R.RM, Across frm M. Office Sink	6.6
2	5/7/2022	RM 4, Teacher Lounge - Sink	5.3
3	5/7/2022	Girls Gang B.RM - Sink A	4.9
4	5/7/2022	Girls Gang B.RM - Sink B	4.4
5	5/7/2022	Boys Gang B.RM - Sink A	4.6
6	5/7/2022	Boys Gang B.RM - Sink B	4.4
7	5/7/2022	Gym Bathroom A - Sink	9.6
8	5/7/2022	Gym Bathroom B - Sink	8.0
9	5/7/2022	Kitchen, Wash - Sink	4.7
10	5/7/2022	Kitchen, Handwash - Sink	8.2
11	5/7/2022	RM 7 - Sink	4.7
12	5/7/2022	RM 9 - Sink	17.6
13	5/7/2022	RM 10 A - Sink	8.3
14	5/7/2022	Staff/Printer RM, 5th GRD - Sink	13.5
15	5/7/2022	Men 5th GRD B.RM - Sink B	4.6
16	5/7/2022	Women 5th GRD B.RM - Sink A	7.6
17	5/7/2022	Women 5th GRD B.RM - Sink C	4.7
18	5/7/2022	RM 13 - Sink	7.1
19	5/7/2022	RM 14 - Sink	6.5
20	5/7/2022	RM 15 - sink	8.2
21	5/7/2022	RM 16 - Sink	5.1
22	5/7/2022	8th GRD, Printer/Staff B.RM - Sink	5.1
23	5/7/2022	RM 20 - Sink #1	10.7
24	5/7/2022	RM 20 - Sink #2	4.4
25	5/7/2022	8 GRD Girl Gang B.Room - Sink A	6.6
26	5/7/2022	8 GRD Girl Gang B.Room - Sink B	4.5
27	5/7/2022	8 GRD, Boy Gang B.Room - Sink A	5.4
28	5/7/2022	RM 21 - SINK	6.9
29	5/7/2022	RM 23 - SINK A	8.4
30	5/7/2022	RM 24 - Sink	7.0
31	5/7/2022	Front, RD Side - Hose Bib	10.0
32	5/7/2022	Outside Faucet, C3 - Hose Bib	39.8
33	5/7/2022	Pre-Treatment - Hose Bib	164.0
34	5/7/2022	After-Treatment - Hose Bib	10.9