

School Fixtures with Elevated Lead Results (exceeding 4 parts per billion)

China Primary Schools

	Collection Date	Collection site	Concentration (ppb)
1	5/7/2022	Kitchen, Sanatize Station A - Sink	17.2
2	5/7/2022	Kitchen, Veggie Wash - Sink	8.0
3	5/7/2022	Kitchen, Dishwash - Sink	9.8
4	5/7/2022	Staff Lounge - Sink	11.6
5	5/7/2022	Staff Lounge - DWF/Sink Combo	31.8
6	5/7/2022	Main Office Work - Sink	4.6
7	5/7/2022	Custodian Office - Sink	9.9
8	5/7/2022	RM 21 - Sink	11.0
9	5/7/2022	RM 22 - Sink	13.2
10	5/7/2022	RM 12 - Sink	9.5
11	5/7/2022	RM 13 - Sink	6.0
12	5/7/2022	RM 14 - Sink	11.0
13	5/7/2022	RM 15 - Sink	10.1
14	5/7/2022	RM 15 - DWF/Sink Combo	8.7
15	5/7/2022	RM 16 - Sink	9.5
16	5/7/2022	RM 16 - DWF/Sink Combo	10.4
17	5/7/2022	RM 17 - Sink	11.3
18	5/7/2022	RM 18 - Sink	7.6
19	5/7/2022	RM 23, Bathroom - Sink	9.9
20	5/7/2022	Rm 23 - Sink	7.8
21	5/7/2022	Rm 23 - DWF/Sink Combo	16.8
22	5/7/2022	Guidance - Sink	18.8
23	5/7/2022	RM 31 - Sink	21.3
24	5/7/2022	RM 33 - Sink	15.7
25	5/7/2022	RM 28 - Sink	8.5
26	5/7/2022	RM 29 - Sink	10.6
27	5/7/2022	RM 30 - Sink	14.8
28	5/7/2022	RM 30 - DWF/Sink Combo	9.8
29	5/7/2022	RM 32 - Sink	15.0
30	5/7/2022	RM 34 - Sink	13.2
31	5/7/2022	RM 35- Sink	11.5
32	5/7/2022	RM 36- Sink	13.4
33	5/7/2022	RM 37- Sink	10.7
34	5/7/2022	Outside, Near Boiler, Playground - Hosebib	19.8